



City of Wimberley

Environmental Health Department

221 Stillwater Drive, PO Box 2027, Wimberley, Texas 78676

Phone: (512) 847-0025 Fax: (512) 847-0422 Web: www.cityofwimberley.com

CITY OF WIMBERLEY HEALTH INSPECTION FORM FOR CHILD CARE FACILITIES SUBJECT TO REGULATION BY THE: TEXAS DEPARTMENT OF PROTECTIVE AND REGULATORY SERVICES

MORE THAN 12 CHILDREN

Circle one: (Day Care, Kindergarten, and Nursery School, Kindergarten and Above, Institutional Basic Child Care, Institutional Mentally Retarded, Residential Treatment Center, Halfway house, Emergency Shelter)

NAME OF FACILITY: _____ COUNTY: _____

ADDRESS: _____

PERSON IN RESPONSIBLE CHARGE: _____

NAME AND ADDRESS OF TDPRS: _____

CITY OF WIMBERLEY ENVIRONMENTAL HEALTH DIRECTOR: _____

AGE RANGE OF CHILDREN: _____ NUMBER OF CHILDREN ENROLLED AT THIS DATE: _____

LICENSED NUMBER OF CHILDREN: _____ COMMERCIAL: _____ NON-PROFIT: _____

INSPECTING PURPOSE: LICENSE _____ NEW _____ RENEWAL _____ COMPLAINT _____

DATE OF LAST INSPECTION _____ NUMBER OF CORRECTIONS NOTED THIS INSPECTION _____

INSPECTED BY: _____ DATE: _____ TIME: _____

APPROVED: _____

X INDICATED "DEFICIENCY"

BUILDING AND EQUIPMENT

Establishment clean and well maintained.....
Outdoor area clean, well-drained and maintained.....
Each child has own bed, cot, or mat as required.....
Mattresses have covers or protectors.....
Bed linens washed and changed as required.....
Bed linens stored separately.....
Cots and mats cleaned before use by another child*.....
Storage available for each child's personal possessions*.....
Potty chairs emptied and washed after use.....
Hot water controlled by thermostat.....
Hot & cold running water available in bathrooms and kitchen.....

Equipment clean and properly stored.....
Food service and preparation areas clean and easily cleanable.....
Gas ranges vented to the outside.....
Eating and cooking utensils properly sanitized.....
Single service items used only once.....
Linens washed after each use.....
Pets not allowed in food service areas.....
Light fixtures equipped with bulb covers.....
Fruits and vegetables washed.....
Sugar packaged or in closed dispensers.....

VENTILATION, LIGHTING AND HEATING

Lighting satisfactory.....
Room temperature satisfactory.....
No objectionable odors or humidity.....
Windows and doors used for ventilation screened.....

TOILET FACILITIES

Day care facility 1 toilet & 1 lavatory/17 children.....
Urinal substitution not over 50%.....
Institutions, Emergency Shelter, Halfway Houses, Residential.....
Treatment Centers 1 toilet & 1 lavatory & tub or showers/8
Children.....
Potty chairs emptied and washed after use.....
Bathrooms cleaned daily.....
Bathrooms have easily cleanable surfaces.....
Toilet facilities provided for infants.....
Soap and toilet paper available.....
Each child has own clean towel or single use towels available.....

WATER SUPPLY Public _____ Private _____

Private sewage system functions properly.....
Water fountains have guarded angular strength.....

SWIMMING POOLS

Swimming pools properly maintained.....
Swimming pools fenced.....
Gate locked when no in use.....
Chemical store rooms locked when no in use.....
Splashing and wading poop properly maintained.....
Life saving equipment at swimming pool provided.....

SOLID WASTE

Adequate number covered garbage containers.....
Garbage stored outside play area*.....
Garbage containers clean.....
Garbage removed twice per week.....
Garbage disposal satisfactory.....

PETS

Statement from veterinarian on annual pet examination available....
Pets vaccinated for rabies, and other diseases.....
Pets free of ectoparasites.....
Pet living quarters clean.....
Stray animals not present.....

INSECTS AND RODENTS

Grounds free of mosquito breeding sources.....
Grounds free of rodent harborage.....
Pesticides properly used.....
Pesticides and chemicals in locked storage or out of reach.....
Insects and rodents controlled inside facility.....

FOOD SANITATION

Food obtained from approved sources.....
Milk & milk products Grade A pasteurized or otherwise approval.....
Hot foods held at 140°F. or above.....
Refrigeration 45°F. or below. Freezes 0°. or below.....
Food stored off floor and in covered containers.....
Cleaning agents & chemicals labeled & separated from food.....
Food served promptly and refrigerated after use.....
Perishables served within 48 hours.....
Refrigerated medication in separate container.....
Food service personnel free of infectious conditions.....
Food storage and preparation areas adequate and clean.....
Food preparation equipment adequate.....
Walls and ceilings clean and in good repair.....

• Required in less than 24 hour facility

City of Wimberley
Environmental Health Department
221 Stillwater
P.O. Box 2027
Wimberley, Texas 78676
Office (512) 847-0025
Fax (512) 847-0422