

**ADDENDUM NO. 2
TO
CONTRACT DOCUMENTS, TECHNICAL SPECIFICATIONS, AND DRAWINGS
FOR
THE CITY OF WIMBERLEY**

WASTEWATER TREATMENT PLANT PROJECT

TO: PROSPECTIVE OFFERORS AND PLAN HOLDERS

The Contract Documents, Technical Specifications, and Drawings listed below shall be removed in their entirety and replaced with the attached documents to this addendum incorporating the following modifications:

I. Contract Documents

1. Section 00411 – Bid Schedule
 - A. Page 4 – Time of Completion: The contract time has been extended to 260 days.
 - B. Page 3 – Alternate Bid Item No. 7: The description was updated to:
“500,000 Gallon Reclaimed Water Storage Tank, Bolted Steel Tank, Open Top”
2. Section 00520 – Agreement
 - A. Article 4.2: The contract time has been extended to 260 days.
 - B. Article 4.3: Paragraph 4.3.B has been updated to indicate that the Contractor shall pay \$2000 for each calendar day that expires after the time specified for Substantial Completion and \$4000 for each calendar day that expires after the time specified for final payment.

II. Technical Specifications

1. Section 11074 – Pump, End Suction Centrifugal
 - A. Paragraph 2.2.A.1: Update paragraph as follows “Horizontal end suction centrifugal pump, closed coupled unit complete with motor and appurtenances or frame-mounted units, meeting specifications herein and meeting the required pump performance.”
 - B. Pump Data Sheet: Total Head for the transfer pumps shall be 20.6 ft and Total Head for the reclaimed water pumps shall be 267 ft.
2. Section 11390 – Package Membrane Bioreactor Wastewater Treatment Plant
 - A. Paragraph 1.12.B.3: Update paragraph as follows “SUPPLIER’s warranty, should CONTRACTOR be delayed, will not extend beyond 36 months after delivery of equipment, without adjustment in contract price.”
 - B. Paragraph 2.7.2.2: Update paragraph as follows “Blowers will be positive displacement blowers or regenerative type blowers with inlet and outlet silencers...”
 - C. Paragraph 2.10.E: Add Glasco UV LLC to the list of approved manufacturers for the Ultraviolet Disinfection System.
 - D. Paragraph 2.17: Modify paragraph to allow for either an ultrasonic level transmitter or magnetic flow meter as a secondary effluent flow metering device.
3. Section 15105 – Valves, Air Release
 - A. Add the attached Specification Section 15105 to the contract documents and table of contents.

III. Drawings

No addendum items.

All items in conflict with this addendum are hereby deleted.

THIS ADDENDUM IS MADE PART OF THE SPECIFICATIONS AND CONTRACT DOCUMENTS, AND SHALL BE ACKNOWLEDGED ON THE COST PROPOSAL FORM AND ON THE PROPOSAL ENVELOPE.

ALAN PLUMMER ASSOCIATES, INC
TBPE Firm No. 13

Stephen J. Coonan

Stephen J. Coonan, P.E.
April 17, 2017

